

GIS REGISTRY INFORMATION

SITE NAME:	Speedy Lube			FID #	
BRRTS #:	03-68-003611			(if appropriate):	
COMMERCE # <small>(if appropriate):</small>	53188-3604-18				
CLOSURE DATE:	July 9, 2004				
STREET ADDRESS:	518 Delafield St				
CITY:	Waukesha				
SOURCE PROPERTY GPS COORDINATES <small>(meters in WTM91 projection):</small>	X =	663519	Y =	284309	
CONTAMINATED MEDIA:	Groundwater	<input type="checkbox"/>	Soil	<input type="checkbox"/>	Both <input checked="" type="checkbox"/>
OFF-SOURCE GW CONTAMINATION >ES:	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	
• IF YES, STREET ADDRESS:					
• GPS COORDINATES <small>(meters in WTM91 projection):</small>					
	X =		Y =		
OFF-SOURCE SOIL CONTAMINATION >Generic or Site-Specific RCL (SSRCL):	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	
• IF YES, STREET ADDRESS 1:					
• GPS COORDINATES <small>(meters in WTM91 projection):</small>					
	X =		Y =		
CONTAMINATION IN RIGHT OF WAY:	Yes	<input checked="" type="checkbox"/>	Potential	No	<input type="checkbox"/>
<u>DOCUMENTS NEEDED</u>					
Closure Letter, and any conditional closure letter issued					<input checked="" type="checkbox"/>
Copy of most recent deed, including legal description, for all affected properties					<input checked="" type="checkbox"/>
Certified survey map or relevant portion of the recorded plat map <i>(if referenced in the legal description)</i> for all affected properties					<input checked="" type="checkbox"/>
County Parcel ID number, <i>if used for county</i> , for all affected properties					<input checked="" type="checkbox"/>
Location Map which outlines all properties within contaminated site boundaries on USGS topographic map or plat map in sufficient detail to permit the parcels to be located easily (8.5x14" if paper copy). If groundwater standards are exceeded, the map must also include the location of all municipal and potable wells within 1200' of the site.					<input checked="" type="checkbox"/>
Detailed Site Map(s) for all affected properties , showing buildings, roads, property boundaries, contaminant sources, utility lines, monitoring wells and potable wells. (8.5x14", if paper copy) This map shall also show the location of all contaminated public streets, highway and railroad rights-of-way in relation to the source property and in relation to the boundaries of groundwater contamination exceeding ch. NR 140 ESs and soil contamination exceeding ch. NR 720 generic or SSRCLs.					<input checked="" type="checkbox"/>
Tables of Latest Groundwater Analytical Results (no shading or cross-hatching)					<input checked="" type="checkbox"/>
Tables of Latest Soil Analytical Results (no shading or cross-hatching)					<input checked="" type="checkbox"/>
Isoconcentration map(s), <i>if required for site investigation (SI)</i> (8.5x14" if paper copy). The isoconcentration map should have flow direction and extent of groundwater contamination defined. If not available, include the latest extent of contaminant plume map.					<input checked="" type="checkbox"/>
GW: Table of water level elevations, with sampling dates, and free product noted if present					<input checked="" type="checkbox"/>
GW: Latest groundwater flow direction/monitoring well location map (should be 2 maps if maximum variation in flow direction is greater than 20 degrees)					<input checked="" type="checkbox"/>
SOIL: Latest horizontal extent of contamination exceeding generic or SSRCLs, with one contour					<input checked="" type="checkbox"/>
Geologic cross-sections, <i>if required for SI</i> . (8.5x14" if paper copy)					<input checked="" type="checkbox"/>
RP certified statement that legal descriptions are complete and accurate					<input checked="" type="checkbox"/>
Copies of off-source notification letters (if applicable) – source property owner					<input checked="" type="checkbox"/>
Letter informing ROW owner of residual contamination (if applicable)(public, highway or railroad ROW)					<input checked="" type="checkbox"/>
Copy of (soil or land use) deed restriction(s) or deed notice <i>if any required as a condition of closure</i>					<input type="checkbox"/>



ENVIRONMENTAL & REGULATORY SERVICES DIVISION
BUREAU OF PECFA
101 West Pleasant Street, Suite 100A
Milwaukee, Wisconsin 53212-3963
TDD #: (608) 264-8777
Fax #: (414) 220-5374
Jim Doyle, Governor
Cory L. Nettles, Secretary

July 9, 2004

Mr. Chester Bojanowski
Southeast Petroleum Company
P.O. Box 1385
Waukesha, WI 53187-1385

RE: **Final Closure**

Commerce # 53188-3604-18 WDNR BRRTS # 03-68-003611
Speedy Lube, 518 Delafield Street, Waukesha

Dear Mr. Bojanowski:

The Wisconsin Department of Commerce (Commerce) has received all items required as conditions for closure of the site referenced above. This case is now listed as "closed" on the Commerce database and will be included on the Wisconsin Department of Natural Resources (WDNR) Geographic Information System (GIS) Registry of Closed Remediation Sites to address residual soil and groundwater contamination. It is in your best interest to keep all documentation related to the environmental activities that were conducted.

If residual contamination is encountered in the future, it must be managed in accordance with all applicable state and federal regulations. If it is determined that any remaining contamination poses a threat, the case may be reopened and further investigation or remediation may be required.

Thank you for your efforts to bring this case to closure. If you have any questions, please contact me in writing at the letterhead address or by telephone at (414) 220-5376.

Sincerely,

A handwritten signature in black ink, appearing to read "L.M.", followed by a stylized flourish.

Linda M. Michalets
Hydrogeologist
Site Review Section

cc: Mr. Bhuvanesh Singh, K. Singh & Associates, Inc.
Case File



ENVIRONMENTAL & REGULATORY SERVICES DIVISION
BUREAU OF PECFA
101 West Pleasant Street, Suite 100A
Milwaukee, Wisconsin 53212-3963
TDD #: (608) 264-8777
Fax #: (414) 220-5374
Jim Doyle, Governor
Cory L. Nettles, Secretary

March 30, 2004

Mr. Chester Bojanowski
Southeast Petroleum Company
P.O. Box 1385
Waukesha, WI 53187-1385

RE: **Conditional Case Closure**

Commerce # 53188-3604-18 **WDNR BRRTS # 03-68-003611**
Speedy Lube, 518 Delafield Street, Waukesha

One 3,000-gallon premium unleaded gasoline underground storage tank (UST) abandoned in place in 1996 and one 550-gallon waste oil UST removed in 1998

Dear Mr. Bojanowski:

The Wisconsin Department of Commerce (Commerce) has reviewed the request for case closure prepared by your consultant, K. Singh & Associates, Inc., for the site referenced above. It is understood that residual soil and groundwater contamination remains on-site. Commerce has determined that this site does not pose a significant threat to the environment and human health. No further investigation or remedial action is necessary.

The following condition must be satisfied to obtain final closure:

- The six remaining monitoring wells must be properly abandoned and the appropriate documentation forwarded to me at the letterhead address.

This letter serves as your written notice of "no further action". Timely filing of your final PECFA claim (if applicable) is encouraged. If your claim is not received within 120 days of the date of this letter, interest costs incurred after 60 days of the date of this letter will not be eligible for PECFA reimbursement.

Thank you for your efforts to protect Wisconsin's environment. If you have any questions, please contact me in writing at the letterhead address or by telephone at (414) 220-5376.

Sincerely,

A handwritten signature in black ink, appearing to read "Linda M. Michalets".

Linda M. Michalets
Hydrogeologist
Site Review Section

cc: Mr. Bhuvanesh Singh, K. Singh & Associates, Inc.
Case File

2181149

STATE BAR OF WISCONSIN FORM 3 - 1982
QUIT CLAIM DEED

DOCUMENT NO.

REGISTER'S OFFICE
WAUKESHA COUNTY, WIS. } SS
RECORDED IN

96 DEC 30 PM 12:34
REEL 2367 IMAGE 0366

Elizabeth A. Truesdale
REGISTER OF DEEDS

2181149

Efthimia Pappas, a single person,

quit-claims to Deanna Schultz, a single person,
Ellen E. Christensen, a married person, as
individual property, and Vangel Pappas, a
single person, as joint tenants with right of
survivorship,

the following described real estate in Waukesha County,
State of Wisconsin:

THIS SPACE RESERVED FOR RECORDING DATA

NAME AND RETURN ADDRESS

Atty. Elizabeth A. Truesdale
TIKALSKY, RAASCH & TIKALSKY
P.O. Box 2149
Waukesha, WI 53187-2149 *pl*

WAKC 1306.339
PARCEL IDENTIFICATION NUMBER

All of Siloam Spring Block as platted in Spence's Hyde Park Addition to the Village of Waukesha, being a part of the Northwest 1/4 of Section 3, Town 6 North, Range 19 East, and the Southwest 1/4 of Section 34, Town 7 North, Range 19 East, in the City of Waukesha, County of Waukesha, State of Wisconsin, except that part taken for street purposes.

FEE
77.25 (5)
EXEMPT

This is not homestead property.
(is) (is not)

Dated this 27th day of December, 19 96.

(SEAL)

Efthimia Pappas (SEAL)
Eftimia Pappas

(SEAL)

(SEAL)

AUTHENTICATION

Signature of Efthimia Pappas

authenticated this 27th day of December, 19 96

Elizabeth A. Truesdale
Elizabeth A. Truesdale

TITLE: MEMBER STATE BAR OF WISCONSIN

(If not, _____
authorized by §706.06, Wis. Stats.)

THIS INSTRUMENT WAS DRAFTED BY
Atty. Elizabeth A. Truesdale
State Bar No. 1011564
Waukesha, WI 53186

(Signatures may be authenticated or acknowledged. Both are not necessary.)

ACKNOWLEDGMENT


State of Wisconsin, } ss.

Personally came before me this _____ day of _____, 19____, the above named

to me known to be the person _____ who executed the foregoing instrument and acknowledge the same.


Notary Public, _____ County, Wis.
My commission is permanent. (If not, state expiration date: _____, 19____.)


* Names of persons signing in any capacity should be typed or printed below their signatures.



9'05"	1	9'05"
9'05"	2	9'05"
9'05"	3	9'05"
9'05"	4	9'05"
9'05"	5	9'05"
9'05"	6	9'05"
9'05"	7	9'05"
9'05"	8	9'05"

1.8.730 feet
51 ft





Note: Plotted contours based on elevation data collected 02/05/02.

LEGEND				
	Area of Remedial Excavation			
	Monitoring Well Location			
	Groundwater Recovery Well			

Figure 1: Monitoring Well Location Map				
Date	Drawn by	Revised by	Date	Project No.
April 1, 1998	M.K.J.			4003
	Checked by	M.K.J.	September 18, 1998	Sheet No.
	P.N.S.			One



Owner
Speedy Lube
 Speedy Lube Gas Station
 518 Delafield Street
 Waukesha WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
 Engineers & Environmental Management Consultants
 1135 Legion Drive, Elm Grove, Wisconsin 53122, (262) 821-1171

Table 1
Groundwater Monitoring Data with Water Level
Speedy Lube Gas Station - Waukesha, 518 Delafield Street (Pr. # 4003)
Monitoring Well MW-1

Date	Benzene	Ethylbenzene	Methyl-t-butyl ether	Toluene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	Xylene, Total	GRO	Depth to Water	Water Level*
	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	(ft)	(ft msl)
MW-1	Top of Well Screen (msl): 663.52, Length of Well Screen: 10'									
01/29/98	<0.5	<0.5	<i>31</i>	<0.5	<1	<1	<0.5	<0.05	9.96	658.56
07/16/98	<6.3	<0.5	32	0.87	<1	<1	1.7	0.13	10.25	658.27
10/13/99	<i>3.0</i>	<0.5	28	<0.05	<1	<1	<0.5	0.058	10.35	658.17
05/18/00	<i>0.74</i>	<0.22	24	0.25	<0.22	<0.29	0.24	0.056	9.97	658.55
08/25/00	0.31	<0.22	<10	<0.2	<0.22	<0.29	<0.23	<0.05	9.08	659.44
12/20/00	0.41	<0.22	<i>14</i>	0.31	<0.22	<0.29	0.26	<0.05	10.38	658.14
04/25/01	3.5	<0.22	11	0.25	<0.22	<0.29	0.24	NT	9.95	658.57
02/05/02	<0.5	<0.5	10.7	<0.5	<1	<1	<0.5	NT	10.54	657.98
05/21/02	2.2	<0.5	12.0	<0.50	<1	<1	<0.5	NT	10.2	658.32
09/06/02	<0.50	1	9.8	<0.50	2	1.12	0.6	NT	10.14	658.38
12/18/02	<0.50	<0.50	0.7	<0.50	3	1.08	0.7	NT	10.14	658.38
PAL	0.5	140	12	200	96		1,000	---		
ES	5	700	60	1,000	480		10,000	---		

Notes: PAL - Preventative Action Limits, March, 2000. No. 531
 ES - Enforcement Standard, March, 2000. No. 531
 Bold Italic: Exceeds NR 140 ES

NT - Not Tested.

Italic: Exceeds NR 140 PAL

Table 1 (Continued)
 Groundwater Monitoring Data with Water Level
 Speedy Lube Gas Station - Waukesha, 518 Delafield Street (Pr.# 4003)
 Monitoring Well MW-2

Date	Benzene	Ethylbenzene	Methyl-t-butyl ether	Toluene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	Xylene, Total	GRO	Depth to Water	Water Level*
	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	(ft)	(ft msl)
MW-2	Top of Well Screen (msl): 664.05, Length of Well Screen: 10'									
01/29/98	<6.3	12	<2.5	22	450	120	1,100	3.7	10.48	658.57
07/16/98	<5.0	16	<2.0	20	920	330	1,800	13.0	9.7	659.35
10/13/99	Not Sampled due to presence of free product								9.89	659.16
05/18/00	Not Sampled due to presence of free product								NM	
08/25/00	Not Sampled due to presence of free product								NM	
12/20/00	MW-2 removed 11/15/00 during interim soil remediation								Removed	
RW-1	Top of Well Screen (msl): -, Length of Well Screen: 10'									
04/25/01	33	76	<0.8	9.8	420	12	490	NT	-	-
02/05/02	8.34	16.5	2.31	0.626	27.4	3.54	11.5	NT	9.89	658.97
PAL	0.5	140	12	200	96		1,000	---		
ES	5	700	60	1,000	480		10,000	---		

Notes: PAL - Preventative Action Limits. March, 2000. No. 531

NT - Not Tested.

ES - Enforcement Standard. March, 2000. No. 531

Bold Italic: Exceeds NR 140 ES

Italic: Exceeds NR 140 PAL

Table 1 (Continued)
 Groundwater Monitoring Data with Water Level
 Speedy Lube Gas Station - Waukesha, 518 Delafield Street (Pr.# 4003)
 Monitoring Well MW-3

Date	Benzene	Ethylbenzene	Methyl-t-butyl ether	Toluene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	Xylene, Total	GRO	Depth to Water	Water Level*
	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	(ft)	(ft msl)
MW-3	Top of Well Screen (msl): 664.61, Length of Well Screen: 10'									
01/29/98	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	<0.05	10.36	659.25
07/16/98	<0.5	1.4	<0.2	0.75	49	19	47	0.85	10.08	659.53
10/13/99	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	<0.05	9.89	659.72
05/18/00	<0.13	<0.22	<0.16	0.21	<0.22	<0.29	<0.23	<0.05	9.76	659.85
08/25/00	0.95	<0.22	<4	<0.2	<0.22	<0.29	<0.23	<0.05	9.65	659.96
12/20/00	0.13	<0.22	2.2	<0.2	<0.22	<0.29	<0.23	<0.05	10.2	659.41
04/25/01	0.16	<0.22	0.74	0.39	<0.22	<0.29	0.3	NT	9.28	660.33
02/05/02	<0.5	<0.5	0.988	<0.5	<1	<1	<0.5	NT	10.32	659.29
05/21/02	<0.50	<0.50	2.720	<0.5	<1	<1	<0.5	NT	9.75	659.86
PAL	0.5	140	12	200	96		1,000	---		
ES	5	700	60	1,000	480		10,000	---		

Notes: PAL - Preventative Action Limits. March, 2000. No. 531

NT - Not Tested.

ES - Enforcement Standard. March, 2000. No. 531

Bold Italic: Exceeds NR 140 ES

Italic: Exceeds NR 140 PAL

Table 1 (Continued)
 Groundwater Monitoring Data with Water Level
 Speedy Lube Gas Station - Waukesha, 518 Delafield Street (Pr. # 4003)
 Monitoring Well MW-4

<i>Date</i>	<i>Benzene</i>	<i>Ethylbenzene</i>	<i>Methyl-t-butyl ether</i>	<i>Toluene</i>	<i>1,2,4-Trimethylbenzene</i>	<i>1,3,5-Trimethylbenzene</i>	<i>Xylene, Total</i>	<i>GRO</i>	<i>Depth to Water</i>	<i>Water Level*</i>
	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	(ft)	(ft msl)
MW-4	Top of Well Screen (msl): 663.88, Length of Well Screen: 10'									
01/29/98	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	<0.05	10.38	658.5
07/16/98	<0.5	<0.5	<0.2	0.67	4.3	1.4	6.7	0.22	10.12	658.76
10/13/99	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	<0.05	10.23	658.65
05/18/00	<0.13	<0.22	<0.16	<0.2	<0.22	<0.29	<0.23	<0.05	9.86	659.02
08/25/00	<0.13	<0.22	0.59	<0.2	0.25	<0.29	0.32	<0.05	9.86	659.02
12/20/00	2.5	<0.22	<0.16	0.32	4.4	0.94	12	0.11	10.3	658.58
04/25/01	<0.13	<0.22	<0.16	<0.2	<0.22	<0.29	<0.23	NT	9.64	659.24
02/05/02	<0.5	<0.5	11.5	<0.5	<1	<1	<0.5	NT	10.39	658.49
05/21/02	<0.50	<0.5	<0.2	<0.5	<1	<1	<0.5	NT	9.89	658.99
PAL	0.5	140	12	200	96		1,000	---		
ES	5	700	60	1,000	480		10,000	---		

Notes: PAL - Preventative Action Limits. March, 2000. No. 531
 ES - Enforcement Standard. March, 2000. No. 531
 Bold Italic: Exceeds NR 140 ES

NT - Not Tested.

Italic: Exceeds NR 140 PAL

Table 1 (Continued)
 Groundwater Monitoring Data with Water Level
 Speedy Lube Gas Station - Waukesha, 518 Delafield Street (Pr. # 4003)
 Monitoring Wells B-12 and MW-5

Date	Benzene	Ethylbenzene	Methyl-t-butyl ether	Toluene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	Xylene, Total	GRO	Depth to Water	Water Level*
	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	(ft)	(ft msl)
B-12	Top of Well Screen (msl): , Length of Well Screen: 10'									
03/10/98	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	<0.05		
MW-5	Top of Well Screen (msl): , Length of Well Screen: 10'									
03/11/98	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	<0.5		
07/16/98	<i>0.93</i>	2.0	<0.2	6.6	3.8	1.2	11	0.146	10.34	658.44
08/25/00	<0.13	<0.22	<0.16	<0.2	<0.22	<0.29	<0.23	<0.05	9.98	658.8
12/20/00	<0.13	<0.22	<0.16	<0.2	<0.22	<0.29	<0.23	<0.05	10.3	658.48
04/25/01	<0.13	<0.22	<0.16	<0.2	<0.22	<0.29	<0.23	NT	9.39	659.39
02/05/02	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	NT	10.36	658.42
05/21/02	<0.5	<0.5	<0.2	<0.5	<1	<1	<0.5	NT	9.93	658.85
PAL	0.5	140	12	200	96		1,000	---		
ES	5	700	60	1,000	480		10,000	---		

Notes: PAL - Preventative Action Limits. March, 2000. No. 531

NT - Not Tested.

ES - Enforcement Standard. March, 2000. No. 531

Bold Italic: Exceeds NR 140 ES

Italic: Exceeds NR 140 PAL

Table 1 Continued
 Groundwater Monitoring Data with Water Level
 Speedy Lube Gas Station - Waukesha, 518 Delafield Street (Pr. # 4003)
 Monitoring Well MW-6

<i>Date</i>	<i>Benzene</i>	<i>Ethylbenzene</i>	<i>Methyl-t-butyl ether</i>	<i>Toluene</i>	<i>1,2,4-Trimethylbenzene</i>	<i>1,3,5-Trimethylbenzene</i>	<i>Xylene, Total</i>	<i>GRO</i>	<i>Depth to Water</i>	<i>Water Level*</i>
	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	(ft)	(ft, msl)
MW-6	Top of Well Screen (msl): , Length of Well Screen: 10'									
07/16/98	3,700	2,600	2,100	17,000	2,000	690	14,000	51		
10/13/99	1,200	700	150	1,400	690	27	1,600	7.4	10.36	659.6
05/18/00	650	510	530	1,200	570	75	1,900	8.4	10.01	659.95
08/25/00	840	550	630	1,100	520	49	1,600	7.5	9.95	660.01
12/20/00	1,300	1,000	950	1,600	940	140	3,500	15	10.4	659.56
04/25/01	420	380	240	1,100	360	55	1,600	NT	9.69	660.27
02/05/02	159	221	143	33.6	220	15.8	398	NT	10.53	659.43
05/21/02	215	255	47	538.0	291	50.1	1,090	NT	9.96	660
09/06/02	537	463	462	444.0	431	45	1,190	NT	9.93	660.03
12/18/02	1,250	1,040	851	1,170	934	128	3,340	NT	10.25	659.71
PAL	0.5	140	12	200	96		1,000	---		
ES	5	700	60	1,000	480		10,000	---		

Notes: PAL - Preventative Action Limits. March, 2000. No. 531

NT - Not Tested.

ES - Enforcement Standard. March, 2000. No. 531

Bold Italic: Exceeds NR 140 ES

Italic: Exceeds NR 140 PAL

Table 1 (Continued)
 Groundwater Monitoring Data with Water Level
 Speedy Lube Gas Station - Waukesha, 518 Delafield Street (Pr. # 4003)
 Monitoring Well MW-7

<i>Date</i>	<i>Benzene</i>	<i>Ethylbenzene</i>	<i>Methyl-t-butyl ether</i>	<i>Toluene</i>	<i>1,2,4-Trimethylbenzene</i>	<i>1,3,5-Trimethylbenzene</i>	<i>Xylene, Total</i>	<i>GRO</i>	<i>Depth to Water</i>	<i>Water Level*</i>
	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	(ft)	(ft msl)
MW-7	Top of Well Screen (msl): , Length of Well Screen: 10'									
05/21/02	<0.5	<0.5	13	<0.5	<1	<1	<0.5	NT	10	659.21
09/06/02	<0.50	<0.50	11.20	<0.50	<1.0	<1.0	0.6	NT	10.02	659.19
12/18/02	<0.50	<0.50	<0.20	<0.50	<1.0	<1.0	<0.50	NT	10.1	659.11
PAL	0.5	140	12	200	96		1,000	--		
ES	5	700	60	1,000	480		10,000	--		

Notes: PAL - Preventative Action Limits, March, 2000. No. 531
 ES - Enforcement Standard. March, 2000. No. 531
 Bold Italic: Exceeds NR 140 ES

NT - Not Tested.

Italic: Exceeds NR 140 PAL

Table 4
Groundwater Quality Intrinsic Biodegradation Parameters

Date	Sample No.	Dissolved Oxygen	ORP	pH	Temperature	Nitrate	Sulfate	Iron
		mg/L	mV		Degree C	mg/L	mg/L	mg/L
1/29/98	MW-1	2.35	-3	6.88	11.7	1.80	52	0.22
1/29/98	MW-2	2.10	-8	6.89	11.3	1.70	77	0.61
1/29/98	MW-3	2.28	-13	6.94	10.6	0.36	52	2.00
1/29/98	MW-4	4.35	-17	7.03	9.2	2.3	62	<0.005
3/11/98	MW-5	8.40	-8	6.85	7.2	NT	92	0.08

Table 5
Summary of Soil Quality Test Results

Date Collected	Sample No.	Total Lead	Benzene	Ethylbenzene	Methy-t-butyl ether	Toluene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	Xylenes, total	GRO	DRO	HNU Reading
		ppm	ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppm	ppm	
1/27/98	B-1, S-4, 8.5'-10.0'	4.8	<25	<25	<25	<25	270	92	150	<5.5	NT	BK
1/27/98	B-2, S-4, 8.5'-10.0'	38	<250	<250	<250	3,900	130,000	51,000	110,000	4,700	NT	250
1/27/98	B-3, S-4, 8.5'-10.0'	6.3	<25	<25	<25	<25	<25	<25	<25	<5.0	NT	BK
1/27/98	B-4, S-4, 8.5'-10.0'	5.4	<25	<25	<25	82	170	61	360	<6.0	NT	BK
1/27/98	B-5, S-4, 8.5'-10.0'	2.0	19,000	<250	5,200	<250	<250	<250	<250	7,900	NT	200
1/27/98	B-6, S-4, 8.5'-10.0'	3.9	<25	<25	<25	<25	<25	<25	<25	<6.2	NT	BK
1/28/98	B-7, S-3, 6.0'-7.5'	13	<25	<25	<25	<25	<25	<25	<25	<5.4	NT	BK
1/28/98	B-8, S-5, 11.0'-12.5'	9	130	3,200	910	870	19,000	8,300	6,800	350	10	200
1/28/98	B-9, S-4, 8.5'-10.0'	4.7	<25	<25	<25	<25	<25	<25	<25	<5.6	NT	BK
1/28/98	B-10, S-3, 6.0'-7.5'	13	<25	<25	<25	<25	<25	<25	<25	<6.0	NT	BK
1/28/98	B-11, S-4, 8.5'-10.0'	8.3	<25	<25	<25	<25	<25	<25	<25	<6.6	NT	BK
3/10/98	B-12, S-4, 8.5'-10.0'	3.5	<25	<25	<25	<25	<25	<25	<25	<5.8	NT	BK
3/10/98	B-13, S-4, 8.5'-10.0'	6	<25	<25	<25	<25	<25	<25	<25	<5.8	NT	BK
1/27/98	Field Blank	NT	<25	<25	<25	<25	<25	<25	<25	<5.0	NT	N/A
1/28/98	Field Blank	NT	<25	<25	<25	<25	<25	<25	<25	<5.0	NT	N/A
3/10/98	Field Blank	NT	<25	<25	<25	<25	<25	<25	<25	<5.0	NT	N/A
BETX: Proposed Criteria		N/A	25	2900	N/A	1500	N/A	N/A	4100	N/A	N/A	N/A

Table 6
 Speedy Lube Gas Station - Waukesha
 518 Delafield Street, Waukesha, WI
 Project 4003


Summary of Soil Quality Test Results - Confirmatory Soil Samples from Remedial Excavation

Date Collected	Sample Location	Depth (feet)	PID Reading (lu)	Benzene (ppb)	Ethylbenzene (ppb)	MTBE (ppb)	Toluene (ppb)	1,2,4-TMB (ppb)	1,3,5-TMB (ppb)	Xylenes (ppb)	GRO (ppm)
11/15/00	S #1	9	115	1,000	857	42.9	150	1,330	958	6,250	35.8
11/15/00	S #2	12	100	<25	52.3	<25	<25	283	104	233	9.07
11/15/00	S #3	9	37	37.5	213	<25	261	1,210	458	3,270	31.3
11/15/00	S #4	14	30	39.9	271	<25	44.4	1,090	329	804	35.5
01/27/98	Soil Boring B-6	8.5-10	BK	<25	<25	<25	<25	<25	<25	<25	<6.2
01/28/98	Soil Boring B-8	11-12.5	200	130	3,200	910	870	19,000	8,300	6,800	350
11/15/00	Staged Soil	---	26	34.8	29	<25	<25	30.7	29.2	160	<6.09
10/04/01	Field Blank	---	---	<25	<25	<25	<25	<25	<25	<75	NT
NR 720.09(4) Standards				5.5	2,900	NA	1,500	NA	NA	4,100	250
NR 746.06(2)(b) Table 1 Standards				8,500	4,600	NA	38,000	83,000	11,000	42,000	NA
NR 746.06(2)(b) Table 2 Standards				1,100	NA	NA	NA	NA	NA	NA	NA
NT - Not Tested NA - Not Applicable BK - Background Concentration											

Table 7
 Speedy Lube Gas Station - Waukesha
 518 Delafield Street, Waukesha, WI
 Project 4003

Summary of Soil Quality Test Results - Composite Sample from Remedial Excavation

Date Collected	Sample Name	Benzene (ppb)	Ethylbenzene (ppb)	MTBE (ppb)	Toluene (ppb)	1,2,4-TMB (ppb)	1,3,5-TMB (ppb)	Xylenes (ppb)	GRO (ppm)
11/15/00	BIO-1	<25	33	<25	61.2	118	52.2	177	6.88



IT-A

Owner
Speedy Lube
 Speedy Lube Gas Station
 518 Delafield Street
 Waukesha WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
 Engineers & Environmental Management Consultants
 1135 Legion Drive, Elm Grove, Wisconsin 53122, (414) 821-1171

Figure 9 Contour Map of Benzene Concentration in Groundwater

Date	Drawn by	Revised by	Date	Project No.
April 1, 1998	M.K.J			4003
	Checked by			Sheet No.
	P.N.S			One



Scale: 0 20 40

Table 2: Summary of Groundwater Elevation Data
Speedy Lube Gas Station - Waukesha, 518 Delafield Street

Monitoring Well	Surface Elevation	PVC Elevation	January 29, 1998		July 16, 1998		October 13, 1999		May 18, 2000		August 25, 2000		December 20, 2000	
			Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation
			feet	feet, MSL	feet	feet/msl	feet	feet/msl	feet	feet/msl	feet	feet/msl	feet	feet/msl
MW-1	668.82	668.52	9.96	658.56	10.25	658.27	10.35	658.17	9.97	658.55	9.08	659.44	10.38	658.14
MW-2	669.47	669.05	10.48	658.57	9.70	659.35	*	*	*	*	*	*	*	*
MW-3	669.98	669.61	10.36	659.25	10.08	659.53	9.89	659.72	9.76	659.85	9.65	659.96	10.2	659.41
MW-4	669.22	668.88	10.38	658.50	10.12	658.76	10.23	658.65	9.86	659.02	9.86	659.02	10.3	658.58
MW-5	669.05	668.78	*	*	10.34	658.44	*	*	*	*	9.98	658.80	10.3	658.48
MW-6	670.20	669.96	*	*	*	*	10.36	659.60	10.01	659.95	9.95	660.01	10.4	659.56
MW-7	669.38	669.21	*	*	*	*	*	*	*	*	*	*	*	*
RW-1	669.05	668.78	*	*	*	*	*	*	*	*	*	*	*	*
Average	669.46	669.13	10.30	658.72	10.10	658.87	10.21	659.04	9.90	659.34	9.70	659.45	10.32	658.83

Monitoring Well	Surface Elevation	PVC Elevation	April 25, 2001		February 5, 2002		May 21, 2002		September 6, 2002		December 18, 2002	
			Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation	Depth to Water	Water Surface Elevation
			feet	feet, MSL	feet	feet/msl	feet	feet/msl	feet	feet/msl	feet	feet/msl
MW-1	668.82	668.52	9.95	658.57	10.54	657.98	10.2	658.32	10.14	658.38	10.14	658.38
MW-2	669.47	669.05	*	*	*	*	*	*	*	*	*	*
MW-3	669.98	669.61	9.28	660.33	10.32	659.29	9.75	659.86	9.76	659.85	10	659.61
MW-4	669.22	668.88	9.64	659.24	10.39	658.49	9.89	658.99	9.87	659.01	10.2	658.68
MW-5	669.05	668.78	9.39	659.39	10.36	658.42	9.93	658.85	10.19	658.59	10.55	658.23
MW-6	670.20	669.96	9.69	660.27	10.53	659.43	9.96	660.00	9.93	660.03	10.25	659.71
MW-7	669.38	669.21	*	*	*	*	10.00	659.21	10.02	659.19	10.1	659.11
RW-1	669.05	668.78	*	*	9.89	658.89	10.02	658.76	*	*	*	*
Average	669.46	669.13	9.59	659.56	10.43	658.72	9.95	659.20	9.98	659.17	10.23	658.92

Note : * Not Measured or Not Installed on this Date



Note: Plotted contours based on elevation data collected 02/05/02.

LEGEND

- Area of Remedial Excavation
- Monitoring Well Location
- Groundwater Recovery Well
- 658.49 Groundwater Elevation (ft. MSL)


Owner
Speedy Lube
 Speedy Lube Gas Station
 518 Delafield Street
 Waukesha WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
 Engineers & Environmental Management Consultants
 1135 Legion Drive, Elm Grove, Wisconsin 53122, (262) 821-1171

Figure . Groundwater Elevation Contour Map - 02/05/02 (Post-Excavation)

Date April 1, 1998	Drawn by M.K.J	Revised by M.K.J	Date September 18, 1998	Project No. 4003
	Checked by P.N.S			Sheet No. One






Note: Plotted contours based on elevation data collected 02/05/02.

LEGEND					
	Proposed Monitoring Well		Area of Remedial Excavation		Monitoring Well Location
	Groundwater Recovery Well				

Figure 2. Groundwater Contours on December 18, 2002				
Date	Drawn by	Revised by	Date	Project No.
April 1, 1998	M.K.J			4003
	Checked by	M.K.J	September 18, 1998	Sheet No.
	P.N.S			One

Owner
Speedy Lube
 Speedy Lube Gas Station
 518 Delafield Street
 Waukesha WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
 Engineers & Environmental Management Consultants
 1135 Legion Drive, Elm Grove, Wisconsin 53122, (262) 821-1171



Note: Plotted contours indicate concentration of benzene determined during remedial investigation.


LEGEND	
	Area of Remedial Excavation
	Preliminary Soil Boring Location
	Soil Boring Location
	Monitoring Well Location

Owner
Speedy Lube
 Speedy Lube Gas Station
 518 Delafield Street
 Waukesha WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
 Engineers & Environmental Management Consultants
 1135 Legion Drive, Elm Grove, Wisconsin 53122, (262) 821-1171

Figure 10 Estimated Extent of Residual Soil Contamination				
Date	Drawn by	Revised by	Date	Project No.
April 1, 1998	M.K.J.	M.K.J.	September 18, 1998	4003
	Checked by			Sheet No.
	P.N.S.			One






LEGEND	
	Area of Remedial Excavation
	Confirmatory Soil Sample Location
	Groundwater Recovery Well
	Soil Boring Location
	Monitoring Well Location

Owner
Speedy Lube
 Speedy Lube Gas Station
 518 Delafield Street
 Waukesha WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
 Engineers & Environmental Management Consultants
 1135 Legion Drive, Elm Grove, Wisconsin 53122, (262) 821-1171

Figure 11 Area of Soil Excavation & Confirmatory Sample Location				
Date	Drawn by	Revised by	Date	Project No.
April 1, 1998	M.K.J			400
	Checked by			Sheet No.
	P.N.S			One




5-A1

Owner
Speedy Lube
 Speedy Lube Gas Station
 518 Delafield Street
 Waukesha WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
 Engineers & Environmental Management Consultants
 1135 Legion Drive, Elm Grove, Wisconsin 53122, (414) 821-1171

Figure 4: Location of Geologic Section Area A-A' and B-B'

Date March 17, 1998	Drawn by MKJ	Revised by	Date	Project No. 4000
	Checked by P.N.S.			Sheet No. One



Legend			
	CL Silty/Sandy Clay		
	SM Silty Sand		
	SP Sand		
	GP Sandy Gravel		
	OH Organic Clay		
	Fill		
	Depth to Water in Soil Boring		
	Depth to Water in Monitoring Well		
*	Benzene Concentrations (ppb)		
\$	GRO Concentrations (ppm)		
&	PID Meter Reading		


Figure 5 - Geologic Section "A-A"

Operator
Speedy Lube

Location:
Speedy Lube Gas Station
518 Delatfield Street
Waukesha, WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
Engineers & Environmental Management Consultants
1135 Legion Drive, Elm Grove, Wisconsin 53122, (414) 821-1171

Date February 19, 1998	Drawn by M.K.J.	Project No. Revised by	4803 Date
Scale 	Checked by P.N.S.		



Legend	
	CL Silty/Sandy Clay
	SM Silty Sand
	SP Sand
	GP Sandy Gravel
	OH Organic Clay
	Fill
	Depth to Water in Soil Boring
	Depth to Water in Monitoring Well
*	Benzene Concentrations (ppb)
\$	GRO Concentrations (ppm)
&	PID Meter Reading

Operator
Speedy Lube

Location:
Speedy Lube Gas Station
518 Delafield Street
Waukesha, WI 53188

Engineer
K. SINGH & ASSOCIATES, INC.,
Engineers & Environmental Management Consultants
1135 Legion Drive, Elm Grove, Wisconsin 53122, (414) 821-1171

Figure 6 - Geologic Section "B-B"			
Date	Drawn by	Project no.	4001
February 19, 1998	M.K.J.	Revised by	Date
Scale	Checked by		
	P.N.S.		

Certification of Legal Descriptions

(Speedy Lube, 518 Delafield Avenue, Waukesha, WI 53188-3604)

All of Siloam Spring Block as platted in Spence's Hyde Park Addition to the Village of Waukesha, being a part of the Northwest 1/4 of Section 3, Town 6 North, Range 19 East, and the Southwest 1/4 of Section 34, Town 7 North, Range 19 East, in the City of Waukesha, County of Waukesha, State of Wisconsin, except that part taken for street purposes.

I CHRISTOPHER J. BOJANOWSKI certify that the legal description provided above and the attached Warranty Deeds are complete and accurate to the best of my knowledge. The legal descriptions correctly describe the parcels affected by petroleum releases from Speedy Lube, 518 Delafield Avenue Waukesha, WI 53188-3604.

Signature

Christopher J. Bojanowski, PARTNER
SPEEDY LUBE

Title

Date

MARCH 12, 2003

**SPEEDY LUBE
720 MAIN STREET
MUKWONAGO, WI 53149
(262-363-3060)**

January 5, 2003

Ms. Deanna Schultz
501 Randall Street, Apt # 1
Waukesha, WI 53186

Subject: Notification of Potential Groundwater Contamination at 518 Delafield Street, Waukesha, WI from Speedy Lube Gas Station, 518 Delafield Street, Waukesha, WI.

Dear Ms. Schultz:

Groundwater contamination that appears to have originated from Speedy Lube Gas Station located at 518 Delafield Street, Waukesha, Wisconsin has potential to migrate onto your (source) property on 518 Delafield Street, Waukesha, WI. Actual groundwater contamination at your property is known, as seven monitoring wells MW-1 through MW-7 and one recovery wells were installed and sampled for eleven rounds. Contaminants levels are below their respective NR 140 Preventive Action Limits in monitoring wells MW-1, MW-3, MW-4, MW-5, and MW-7. There is a exceedance of petroleum contaminants in monitoring wells MW-2, MW-6, and RW-1, but, based on Mann-Kendall statistical test performed on eleven rounds of data shows the contaminants concentration is receding or stable with reference to time. There is a potential for migration of contamination on the property due to enforcement standard exceedances for contaminants. However, the environmental consultants who have investigated this contamination have informed me that the groundwater plume is stable or receding and will naturally degrade over time. I believe that by allowing natural attenuation to complete the cleanup, this site will meet the requirements for case closure that are found in Chapter NR 726 and Chapter Comm 46, Wisconsin Administrative Code. Also, I will be requesting that the Department of Commerce accept natural attenuation as the final remedy for this site and grant closure. Closure means that the Department will not be requiring any further investigation or cleanup action to be taken, other than the reliance on natural attenuation.

Since you are not a responsible property, neither you nor any subsequent owner of your property will be held responsible for investigation or cleanup of this groundwater contamination, as long as you and any subsequent owners comply with the requirements of section 292.13, Wisconsin Statutes, including allowing access to your property for environmental investigation or cleanup if access is required. For further information on the requirements of section 292.13, Wisconsin

Ms. Schultz

Page 2

Statutes, you may call 1-800-367-6076 for calls originating in Wisconsin, or 608-264-6020 if you are calling from out of state or within the Madison Area, to obtain a copy of the Department of Natural Resources' publication #RR-589, Fact Sheet 10: Guidance for Dealing with Properties Affected by Off-Site Contamination.

The Department of Commerce will not review my closure request for at least 30 days after the date of this letter. As an affected property owner, you have the right to contact the Department to provide any technical information that you may have that closure should not be granted for this site. If you would like to submit any information to the Department of Commerce that is relevant to the closure request, you should mail the information to: Ms. Linda Michalets, Hydrogeologist, Wisconsin Department of Commerce, Site Review Section, Environmental & Regulatory Services, Bureau of PECFA, 2129, 101 West Pleasant Street, Suite 100A, Milwaukee, Wisconsin.

If this case is closed, all properties within the site boundaries where groundwater contamination exceeds chapter 140 groundwater enforcement standards will be listed on the Wisconsin Department of Natural Resources' geographic information system (GIS) Registry of Closed Remediation Sites. The information on the GIS Registry includes maps showing the location of properties in Wisconsin where groundwater contamination above chapter 140 enforcement standards was found at the time the case was closed. The GIS Registry will be available to the general public on the Department of Natural Resources' internet web site. Please review the enclosed legal description of your property, and notify me within the next 30 days if the legal description is incorrect.

Should you or any subsequent property owner wish to construct or reconstruct a well on your property, special well construction standards may be necessary to protect the well from the residual groundwater contamination. Any well driller who proposes to construct a well on your property in the future will first need to contact the Drinking Water program within the Department of Natural Resources because your property is located within the designated service area of a municipally owned water system, to determine if there is a need for special well construction standards.


Once the Department makes a decision on my closure request, it will be documented in a letter. If the Department grants closure, you may obtain a copy of this letter by requesting a copy from me, by writing to the agency address given above or by accessing the DNR GIS registry of Closed Remediation Sites on the internet at www.dnr.state.wi.us/org/at/et/geo/gwur. A copy of the closure letter is included as part of the site file on the GIS Registry of Closed Remediation Sites.

If you need more information, you may contact me at Southeast Petroleum Company, 720 Main Street, Mukwonago, WI 53149 (262-363-3060), or you may contact Ms. Linda Michalet, Hydrogeologist, Wisconsin Department of Commerce, Site Review Section,

Ms. Schultz
Page 3

Environmental & Regulatory Services, Bureau of PECFA, 101 West Pleasant Street, Suite 100
A, Milwaukee, Wisconsin 53212-3963.

Sincerely,

A handwritten signature in black ink, appearing to read "Chester Bojanowski", with a long horizontal flourish extending to the right.

Chester Bojanowski
(SPEEDY LUBE)

Enclosure: Summary of Legal Description



K. SINGH & ASSOCIATES, INC.

Engineers, Scientists and Environmental Management Consultants

March 6, 2003

Mr. Paul Day, P.E.
City Engineer
City of Waukesha
130 Delafield Street
Waukesha, WI 53187

Project # 4003

Subject: Notification of Potential Residual Contamination within Right-of-Way of Delafield Avenue, Spring Street, and Randall Street at Speedy Lube Gas Station, 518 Delafield Avenue, Waukesha, .
WDNR BRRTS # 03-68-003611, COMM # 53188-3604-18.

Dear Mr. Day:

The purpose of this letter is to notify City of Waukesha regarding potential residual contamination within the right-of-way of Delafield Avenue, Spring Street, and Randall Street at Speedy Lube Gas Station, 518 Delafield Avenue, Waukesha, Wisconsin..

Monitoring well RW-1 is located at boundary line in the northeast direction of the referenced site (Refer to Attached Figure). As per NR 140 Enforcement Standard (ES) exceedances for benzene noted in monitoring well RW-1. However, there was no exceedances of benzene is noted during seven round of sampling in the monitoring well MW-5, which is in the right-of-way of other side of 518 Delafield Avenue. Based on the residual contamination at site there is a potential for migration of groundwater contamination within right-of-way of Delafield Avenue, Spring Street, and Randall Street. However, contamination in groundwater appears to be decreasing with time. Groundwater quality test results are included in Table 1.

We notify the above details for your information and records. It is our understanding that the residual contamination will be remediated by natural attenuation. Please call us if you have any questions regarding this submittal.

Sincerely,

K. SINGH & ASSOCIATES, INC.

Bhuvanesh Singh
Bhuvanesh Singh, Ph.D.
Staff Engineer

Pratap N. Singh
Pratap N. Singh, Ph.D., P.E.
Project Manager

cc: Mr. Chester Bojanowski / Speedy Lube
Ms. Kamala Singh / PECFA Claim File

4. INVENTORY OF TANK SYSTEMS TO BE ASSESSED

TANK #	CONTENTS IN TANK	STORAGE VOLUME (GALLONS)	LENGTH AND DIAMETER OF TANK	TANK CONSTRUCTION	PIPING LENGTH (FEET)	TANK CONDITION	DATE CLOSED
366197	gasoline	3000	5'x22'	Steel/Glass lined	5	Good	02/25/08
366199	gasoline	12000	9'x25'	Steel/Glass lined	5	Good	02/25/08
366200	gasoline	4000	6'x24'	Steel/Glass lined	10	Good	02/25/08
366201	diesel	6000	6'x30'	Steel/Glass lined	15	Good	02/25/08

5. VISUAL INSPECTION

Weather Conditions: 20 degrees, Overcast

Tank(s) Location: North end of property, north of canopy.

- Site Conditions:
- Stressed or dead vegetation
 - Surface staining
 - Unreported tanks
 - None of the above
 - Other (explain) _____

Excavation Inspection:

Excavation depth: 9-12'

Backfill type: Sand

Native soil type: Sandy gravel

Depth to groundwater: Unknown

Backfill type used to fill in excavation: Stone

- Signs of a Release:
- Free product
 - Odors
 - Oil sheen on water
 - Soil discoloration
 - None of the above
 - Other (explain) _____

6. SOIL SAMPLE LOCATIONS AND RESULTS

SOIL SAMPLE NUMBER	SAMPLE LOCATION	SAMPLE DEPTH (Feet)	SOIL TYPE	FIELD READING (i.u.)	ANALYTICAL PARAMETER TESTED	LABORATORY RESULT (MG/KG)
T-1	Base/Diesel Tank	9	Sandy Gravel	Strong Odors	DRO	186
T-2	Base/Diesel Tank	9	Sandy Gravel	Strong Odors	DRO	182
T-3	Base/Diesel Tank	9	Sandy Gravel	Strong Odors	DRO	<10
T-4	Base/Gasoline Tank	9	Sandy Gravel	Strong Odors	GRO	82
T-5	Base/Gasoline Tank	9	Sandy Gravel	Strong Odors	GRO	600
T-6	Base/Gasoline Tank	9	Sandy Gravel	Strong Odors	GRO	960
T-7	Base/Gasoline Tank	9	Sandy Gravel	Strong Odors	GRO	760
T-8	Base/Gasoline Tank	9	Sandy Gravel	Strong Odors	GRO	165
T-9	Base/Gasoline Tank	12	Sandy Gravel	Strong Odors	GRO	249
T-10	Base/Gasoline Tank	12	Sandy Gravel	Strong Odors	GRO	158
T-11	Base/Gasoline Tank	12	Sandy Gravel	Strong Odors	GRO	309
D-1	Beneath Dispenser Island	3	Sandy Gravel	0	DRO/GRO	<10/<10
D-2	Beneath Dispenser Island	3	Sandy Gravel	0	DRO/GRO	<10/<10
D-3	Beneath Dispenser Island	3	Sandy Gravel	0	DRO/GRO	84.4/<10

7. WASTE MANAGEMENT

TYPE OF WASTE	QUANTITY OF WASTE	WASTE TRANSPORTER/DISPOSAL
<input type="checkbox"/> Water		
<input type="checkbox"/> Product		
<input type="checkbox"/> Sludge		



1" = 40ft



Key

- T-1 = Tank base soil samples
- D-1 = Dispenser Island soil samples

Figure 1
UST and Soil Sample
Location Map
Former Shell Station
518 Delafield St
Waukesha, WI